

2016-17 WYCKOFF PUBLIC SCHOOLS
Lead Water Testing Results
Omega Environmental Services, Inc.

CALVIN COOLIDGE

<u>Sample #</u>	<u>Location</u>	<u>1st draw (FD) or flush (FL)*</u>	<u>Results</u> <u>(ppb)</u>	<u>LCR Action Level (1)</u> <u>(ppb)</u>
1	C1	FD	1.7	15
2	CL2	FD	11.5	15
3	CR3	FD	10.3	15
4	CR4	FL	3.3	15
5	CL5	FL	1.2	15
6	C6	FD	<1.0	15
7	C7	FD	2.6	15
8	C8	FD	<1.0	15
9	C9	FD	<1.0	15
10	C10	FD	1.2	15
11	C11	FD	3.7	15
12	C12	FD	5.3	15
13	C13	FD	4.8	15
14	CNF14	FD	<1.0	15
15	CF15	FD	<1.0	15
16	C16	FL	2.8	15

DWIGHT EISENHOWER

<u>Sample #</u>	<u>Location</u>	<u>1st draw (FD) or flush (FL)*</u>	<u>Results</u> <u>(ppb)</u>	<u>LCR Action Level (1)</u> <u>(ppb)</u>
1	E1	FD	<1.0	15
2	EC2	FD	5	15
3	EC3	FD	1.5	15
4	EC4	FD	1.7	15
5	Ice Machine	FD	<1.0	15
6	E5	FD	2.4	15
7	EMO	FD	2.9	15
8	ER7	FD	3.2	15
9	E9	FD	2.4	15
10	EH10	FD	6.4	15
11	EH11	FD	<1.0	15
12	EL12	FD	<1.0	15
13	E13	FD	4.9	15
14	EHE14	FD	<1.0	15
15	EHE15	FD	<1.0	15
16	EHE16	FD	<1.0	15
17	EHE17	FD	<1.0	15
18	E18	FD	<1.0	15

2016-17 WYCKOFF PUBLIC SCHOOLS
Lead Water Testing Results
Omega Environmental Services, Inc.

19	E19	FD	<1.0	15
20	EL20	FD	<1.0	15
21	ER21	FD	<1.0	15
22	E22	FD	1	15
23	EL23	FD	<1.0	15
24	ER24	FD	<1.0	15
25	E25	FD	<1.0	15
26	E26	FD	2.4	15
27	EL8	FD	1.7	15

GEORGE WASHINGTON

<u>Sample #</u>	<u>Location</u>	<u>1st draw (FD) or flush (FL)*</u>	<u>Results</u> <u>(ppb)</u>	<u>LCR Action Level (1)</u> <u>(ppb)</u>
1	W1	FD	<1.0	15
2	W2	FD	<1.0	15
3	W3	FD	<1.0	15
4	W4	FD	<1.0	15
5	W5	FD	<1.0	15
6	W6	FD	<1.0	15
7	W7	FD	5.5	15
8	WR8	FD	2.5	15
9	WC9	FD	2.8	15
10	WL10	FD	3	15
11	W11	FD	1.4	15
12	W12	FD	<1.0	15
13	W13	FD	<1.0	15

ABRAHAM LINCOLN

<u>Sample #</u>	<u>Location</u>	<u>1st draw (FD) or flush (FL)*</u>	<u>Results</u> <u>(ppb)</u>	<u>LCR Action Level (1)</u> <u>(ppb)</u>
1	L1	FD	1.1	15
2	L2	FD	4.6	15
3	L3	FD	1.4	15
4	L4	FD	1.8	15
5	L5	FD	3.9	15
6	L6F	FD	<1.0	15
7	L7F	FD	<1.0	15
8	L8	FL	12.9	15
9	L9	FD	<1.0	15

**2016-17 WYCKOFF PUBLIC SCHOOLS
Lead Water Testing Results
Omega Environmental Services, Inc.**

SICOMAC

<u>Sample #</u>	<u>Location</u>	<u>1st draw (FD) or flush (FL)*</u>	<u>Results</u> <u>(ppb)</u>	<u>LCR Action Level (1)</u> <u>(ppb)</u>
1	S1	FD	11.7	15
2	S2	FD	2.3	15
3	SF3	FD	<1.0	15
4	SNF4	FD	5	15
5	S5	FD	7.8	15
6	SNF6	FD	5.1	15
7	SF7	FD	<1.0	15
8	SL8	FD	<1.0	15
9	SH9	FD	<1.0	15
10	S10	FD	1.8	15
11	SL11	FD	<1.0	15
12	SH12	FD	<1.0	15
13	S13	FD	4.9	15
14	S14	FD	1.5	15
15	S15	FD	3.6	15

* 11/22/16 First Draw (FD) samples drawn

* 1/9/17 Flush (FL) samples drawn

2016-17 WYCKOFF PUBLIC SCHOOLS
Lead Water Testing Results
Omega Environmental Services, Inc.